

BUILDING SAFETY CERTIFICATE

No. :- 01

Dated: - 18/03/26

Certified that the existing building PM SHRI ATAL UTKRSHT SHRI 1008 GEETA SWAMI, G.I.C., GOPESHWAR at NEAR PETROL PUMP, POLICE LINE, GOPESHWAR, BLOCK DASHOLI, DISTRICT CHAMOLI (PIN CODE 246401) comprised of SCIENCE BLOCK (G+1), COMMERCE BLOCK (G+1), ART BLOCK (G.F.), NCC BUILDING (G.F.), AUDITORIUM HALL, OFFICE BLOCK (G.F.), LABORATORY (G.F.), DEPT. OF PHYSICAL EDUCATION (G.F.), owned/occupied by PM SHRI ATAL UTKRSHT SHRI 1008 GEETA SWAMI GOVT. INTER COLLEGE, GOPESHWAR on the basis of visual inspection only, the building/premises appears to be in serviceable and usable condition verified by the officers concerned of PROVINCIAL DIVISION, PUBLIC WORK DEPARTMENT, GOPESHWAR on DATED- 13/03/2026 in the presence of Mr. KARAMVEER SINGH, PRINCIPAL, PM SHRI ATAL UTKRSHT SHRI 1008 GEETA SWAMI GOVT. INTER COLLEGE, GOPESHWAR, CHAMOLI and that the building/premises is fit for occupancy up to classes XII with effect from 13TH MARCH 2026 for a period of 01 years in accordance with rule and subject to compliance of the specific conditions of as appended.

1. The inner roof in certain portions of the building has been found damaged. Immediate repair/retrofitting shall be carried out and dually verified with the competent engineering agency to restore structural integrity in compliance with applicable norms.
2. Minor cracks have been observed at certain locations in walls and ceiling portions of the building the same shall be retrofitted/ repaired at the earliest through a competent engineering agency, ensuring compliance with NBC norms.
3. Railings installed in the buildings require proper maintenance and upkeep to insure safety and serviceability.
4. Additional truss work has been executed in the building; therefore, its periodic inspection and timely maintenance shall be ensured to maintain safety and compliance with NBC norms.
5. This certification has been issued solely on the basis of visual inspection of the site, and the undersigned shall not be held responsible for any hidden or latent structural defects present in the building.

Issued on DATED- 18/03/2026 at PROVINCIAL DIVISION, PUBLIC WORK DEPARTMENT, GOPESHWAR by

* Strike out whichever is not applicable.

Signature with Seal: -

Name: ER. NAVEEN DHYANI

Designation: - EXECUTIVE ENGINEER

Name & Address of Department/ Office: - PROVINCIAL DIVISION,
PUBLIC WORK DEPARTMENT, GOPESHWAR

Note: This certificate should be signed / Issued by Assistant Engineer & above officer of concerned Govt. Department only.

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

seen
Principal
PM SHRI ATAL UTKRIST
SHRI 1008 GEETA SWAMI
G.I.C. GOPESHWAR CHAMOLI-246401